

**FACILITY INSPECTION TOOL (FIT)  
SCHOOL FACILITY CONDITIONS EVALUATION  
(REV 05/09)**

SCHOOL DISTRICT/COUNTY OFFICE OF EDUCATION <b>Sacramento City Unified School District</b>		COUNTY <b>Sacramento</b>	
SCHOOL SITE <b>Mark Twain Elementary School</b>		SCHOOL TYPE (GRADE LEVELS) <b>K-6</b>	NUMBER OF CLASSROOMS ON SITE <b>19</b>
INSPECTOR'S NAME <b>Sharon Ketcherside</b>	INSPECTOR'S TITLE <b>Supervisor</b>	NAME OF DISTRICT REPRESENTATIVE ACCOMPANYING THE INSPECTOR(S) (IF APPLICABLE) <b>Richard Conn</b>	
DATE AND TIME OF INSPECTION <b>9/21/2009 11:00 AM</b>		WEATHER CONDITION AT TIME OF INSPECTION <b>Sunny and warm</b>	

**PART III: CATEGORY TOTALS AND RANKING** (round all calculations to two decimal places)

TOTAL NUMBER OF AREAS	CATEGORY TOTALS	A. SYSTEMS			B. INTERIOR	C. CLEANLINESS		D. ELECTRICAL	E. RESTROOMS/FOUNTAINS		F. SAFETY		G. STRUCTURAL		H. EXTERNAL	
		GAS LEAKS	MECH/HVAC	SEWER	INTERIOR SURFACES	OVERALL CLEANLINESS	PEST/VERMIN INFESTATION	ELECTRICAL	RESTROOMS	SINKS / FOUNTAINS	FIRE SAFETY	HAZARDOUS MATERIALS	STRUCTURAL DAMAGE	ROOFS	PLAYGROUND /SCHOOL GROUNDS	WINDOWS/ DOORS/ FENCES
↓	Number of ✓'s	16	16	19	10	19	18	5	8	16	18	18	18	16	2	18
	Number of D's	0	0	0	6	0	0	11	0	2	0	0	0	0	1	0
<b>19</b>	Number of X's	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Number of NA's	3	3	0	3	0	1	3	11	1	1	1	3	16	1	
Percent of System in Good Repair Number of ✓'s divided by (Total Areas - "NA's")		100.00%	100.00%	100.00%	62.50%	100.00%	100.00%	31.25%	100.00%	88.89%	100.00%	100.00%	100.00%	100.00%	66.67%	100.00%
<b>Total Percent per Category (average of above)*</b>		<b>100.00%</b>			<b>62.50%</b>	<b>100.00%</b>		<b>31.25%</b>	<b>94.44%</b>		<b>100.00%</b>		<b>100.00%</b>		<b>83.33%</b>	
<b>Rank (Check One)</b> Good=90%-100% Fair=75%-89.99%		<input checked="" type="checkbox"/> GOOD <input type="checkbox"/> FAIR			<input type="checkbox"/> GOOD <input type="checkbox"/> FAIR	<input checked="" type="checkbox"/> GOOD <input type="checkbox"/> FAIR		<input type="checkbox"/> GOOD <input type="checkbox"/> FAIR	<input checked="" type="checkbox"/> GOOD <input type="checkbox"/> FAIR		<input checked="" type="checkbox"/> GOOD <input type="checkbox"/> FAIR		<input checked="" type="checkbox"/> GOOD <input type="checkbox"/> FAIR		<input type="checkbox"/> GOOD <input checked="" type="checkbox"/> FAIR	

\* Note: An extreme deficiency in any area automatically results in a "poor" ranking for that category and a zero for "Total Percent per Category."

<b>OVERALL RATING:</b>	<b>DETERMINE AVERAGE PERCENTAGE OF 8 CATEGORIES ABOVE →</b>	<b>83.94%</b>	<b>SCHOOL RATING * →</b>	<b>Fair</b>
------------------------	---	---------------	--------------------------	-------------

\*\* For School Rating, apply the Percentage Range below to the average percentage determined above, taking into account the rating Description below.

PERCENTAGE	DESCRIPTION	RATING
99%-100%	The school meets most or all standards of good repair. Deficiencies noted, if any, are not significant and/or impact a very small area of the school.	Exemplary
90%-98.99%	The school is maintained in good repair with a number of non-critical deficiencies noted. These deficiencies are isolated, and/or resulting from minor wear and tear, and/or in the process of being mitigated.	Good
75%-89.99%	The school is not in good repair. Some deficiencies noted are critical and/or widespread. Repairs and/or additional maintenance are necessary in several areas of the school site.	Fair
0%-74.99%	The school facilities are in poor condition. Deficiencies of various degrees have been noted throughout the site. Major repairs and maintenance are necessary throughout the campus.	Poor

**COMMENTS AND RATING EXPLANATION:**

school is clean but has several lights and ballast out also carpet in some portables is extremely worn and stained